



# Concession Structure Fire Prevention Checklist



## Extinguisher Requirements

All cooking vendors are required to have at least one extinguisher




- At least one Class “ABC” rated extinguisher with a minimum of a 4A:40BC rating
- Visible current inspection tag
- Fully Charged (gauge indicates full)
- Located within 30 feet of commercial type cooking equipment

Does your cooking operation produce grease-laden vapors? (Grills, fryers) If so, in addition to the portable extinguisher listed above your operation requires;



- At least one Class “K” rated, 6 liter portable extinguisher.
- Visible current inspection tag
- Fully Charged (gauge indicates full)
- Located within 30 feet of commercial type cooking equipment.

Does your cooking operation produce grease-laden vapors required to be exhausted through a commercial kitchen exhaust hood and duct system? If so, in addition to the portable extinguishers listed above your operation requires;



- Commercial kitchen exhaust hood and duct system with an automatic fire extinguishing system and visible current inspection tag

## Compressed Gas

LP/Propane cylinders are properly secured and remain secured by one of the following methods, unless actively being refilled;



- Nested and secured by one or more restraints.
- Secured by one or more restraints to a fixed object.
- Minimum of 10-foot clearance from any trash or combustible material.

## Egress and Emergency Access

- The placement of the concession operation does not interfere with fire lane, fire break, fire hydrant, or exit access of any proximate structures.

All cooking equipment shall be separated from the general public by an approved method. The Fire Marshal’s office shall inspect all food vendor sites for fire & life safety compliance.

Please contact us if you have any questions regarding these requirements or any Fire Prevention questions for your event. Our goal is to assist with fire safety and preparedness through dissemination of fire prevention information and education.